

MAR 02 1993

32/1/20h

DEPT OF ECOLOGY

WATER WELL REPORT
STATE OF WASHINGTONStart Card No. 048264
Water Right Permit No.

(1) OWNER Name ROLLING HILLS/LEE JOHNSON Address 2343 W VAN DAM ROAD COUPEVILLE, WA 98239-

(2) LOCATION OF WELL: County ISLAND

- SE 1/4 NE 1/4 Sec 20 T 32 N., R 1 WM

(2a) STREET ADDRESS OF WELL (or nearest address) 1126 N SIDNEY, OAK HBR

(3) PROPOSED USE: MUNICIPAL

(10) WELL LOG

(4) TYPE OF WORK: Owner's Number of well
(If more than one)
NEW WELL Method: ROTARY

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

(5) DIMENSIONS: Diameter of well 8 inches
Drilled 271 ft. Depth of completed well 271 ft.(6) CONSTRUCTION DETAILS:
Casing installed: 8" Dia. from 0 ft. to 261 ft.
WELDED " Dia. from ft. to ft.
" Dia. from ft. to ft.

MATERIAL	FROM	TO
BROWN CLAY	0	33
BROWN CLAY & GRAVEL	33	57
BLUE CLAY	57	113
GRAVEL SAND & WATER	113	126
BLUE CLAY	126	153
FINE SAND & WATER	153	164
COARSE SAND WATER WOOD CLAY	164	189
FINE SAND & WATER	189	230
COARSE SAND GRAVEL & WATER	230	242
	242	273

Perforations: NO

Type of perforator used	SIZE of perforations	in. by	ft.	in.
perforations from	ft. to	ft.		
perforations from	ft. to	ft.		
perforations from	ft. to	ft.		

Screens: YES

Manufacturer's Name	Model No.
Type STAINLESS STEEL	from 261 ft to 271 ft
Diam. 8 slot size 40	from ft to ft
Diam slot size	

2 ft stick up

Gravel packed: NO
Gravel placed from ft. to ftWell Located According to
Island County Ordinance # 809Surface seal: YES To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? NO
Type of water? Depth of strata ft.
Method of sealing strata off(7) PUMP. Manufacturer's Name
Type H P(8) WATER LEVELS: Land-surface elevation
above mean sea level ... ft.
Static level 118 ft. below top of well Date 01/27/93
Artesian Pressure lbs. per square inch Date
Artesian water controlled by

Work started 01/25/93

Completed 01/27/93

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made? If yes, by whom?
Yield gal /min with ft. drawdown after hrsRecovery data
Time Water Level Time Water Level Time Water LevelDate of test / /
Bailer test gal/min. 113 ft. drawdown after hrs.
Air test 150+ gal/min. w/ stem set at ft. for 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made?

WELL CONSTRUCTOR CERTIFICATION

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME DAHLMAN PUMP & WELL DRILL
(Person, firm, or corporation) (Type or print)

ADDRESS PO BOX 422, BURLINGTON, WA

[SIGNED] *Ted Richter* License No. 0623Contractor's
Registration No. DAHLMPW123LC Date 01/29/93RECEIVED
JUN 11 1993
ISL CTY HEALTH DEPT



WASHINGTON STATE
DEPARTMENT OF
ECOLOGY

Well Tagging Form

Unique Well Tag No: ACA 777

502

RECORD VERIFICATION (check one)

- ☐ Well Report available (please attach this form to the well report and submit it to the Ecology Regional Office near you)
- ☐ Verification inconclusive
- ☐ Well Report not available

WELL OWNERSHIP, IF DIFFERENT FROM WELL REPORT

First Name ROLLING HILLS - CLEONAH

Last Name _____

Street Address _____

City _____

State _____

LOCATION OF WELL, IF DIFFERENT FROM WELL REPORT

Well Address DIRECTLY WEST FROM SEC #2 / SHAWN ROAD - OPEN FIELD

City _____

County _____

T _____ N R _____ W M Sec _____

1/4 of the _____

FOR AGENCY USE ONLY

Latitude _____

Longitude _____

Elevation at land surface _____ feet/meters (circle one)

Additional information, if available

☐ Location marked on topographic map (please attach)

☐ Location marked on air photo (please attach)

- ☐ GPS
- ☐ Topographic Map
- ☐ Survey
- ☐ Computer generated
- ☐ Digital Altimeter
- ☐ Topographic Map
- ☐ Other _____

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

FOR AGENCY USE ONLY

WELL CHARACTERISTICS

Physical Description of well (size or casing type or well housing etc)

8" casing INSIDE GREY SHED w/ SIDING, SLOPED ROOF, CYCLONE FENCE
(~10' x 7' x 12')

Location or Well Identification Tag

Casey

Is supplemental tag needed for ease of identifying well?

☐

Yes

☒

No

Where was tag placed?

D	C	B	A
E	F	G	H
M	L	K	J
N	P	Q	R

Scale 1 24 000 (1" = 2 000')

Indicate the location of the well within the Section by drawing a dot at that point.

SECTION _____

Comments

FOR ECOLOGY WATER RESOURCES PROGRAM ONLY

Permit Right # _____ Date Issued _____

Application

Permit

Certificate

Claim

Exempt